



सत्यमेव जयते

Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo no.:WBFES/PSM/155-1/16

Date: 25-01-2024

From:
Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services

To: J.B. Memorial College of Education (B.Ed & D.El. Ed Course)
Mouza-Kui, P.O. and P.S.-Binpur, Dist.-Paschim Medinipur, Pin-721514

Sub: Fire Safety Certificate of an existing construction of G+III storied Educational Building in the name & style "J.B. MEMORIAL COLLEGE OF EDUCATION (B.ED & D.EL. ED COURSE)" under group Educational Building at Mouza-Kui, P.O. and P.S.-Binpur, Dist.-Paschim Medinipur, Pin-721514.

This is in reference to your application no. 0125189239000016 dated 25-12-2023 regarding the Fire Safety Certificate of an existing construction of G+III storied Educational Building in the name & style "J.B. MEMORIAL COLLEGE OF EDUCATION (B.ED & D.EL. ED COURSE)" under group Educational Building at Mouza-Kui, P.O. and P.S.-Binpur, Dist.-Paschim Medinipur, Pin-721514.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
5. A Fire Control Room including a CCTV system will have to be maintained, which observe all floors of the building.

- 6.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.
 - 7.The employees and security staffs shall be conversant with installed Fire Fighting Equipment's of the building and to operate in the event of Fire and Testing.
 - 8.Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
 - 9.A crew of trained Firemen shall be maintained round the clock for fire safety of the building.
 - 10.Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
 - 11.First-Aid Fire Fighting system shall be provided as per I.S. specification.
 - 12.Arrangement shall have to be made for regular checking, testing and maintenance of all the firefighting installation in the building to keep them in perfectly good working condition at all the times.
 - 13.If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
 - 14.Electrical safety Audit to be conducted at regular interval shall be recorded properly.
 - 15.MCP with Hooter & Fire Alarm Panel shall have to be installed.
 - 16.The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
 - 17.This N.O.C. is valid for 3(Three) year and have to be renewed every 3 (Three) year from the date of issue of this letter.
- Each after 3 (Three)year a certificate is to be obtained from the Divisional Fire Office, West Bengal Fire & Emergency Services, performance of all the life and fire safety arrangements and installation of the building.

Member Convener Kharagpur TEC, Paschim
Medinipur
West Bengal Fire & Emergency Services